



Issue Date:	January 1, 2021
Code/Section:	2018 IBC; Section 1108.2.2, Table 1108.2.2.1, 1108.2.9, 1004.6, ICC A117.1 Section 902
Developed By:	Rost Sapon, Accessibility Technical Lead

At least 5 percent, but not less than that specified by Table 1108.2.2.1, of the dining and drinking surfaces with fixed seating (booths, bar counters) shall be provided with wheelchair spaces. An accessible dining surface per ICC A117.1 Section 902 shall be provided at each wheelchair space. The wheelchair space shall provide a minimum 30" X 48" clear floor space, except a 36" X 48" clear floor space shall be provided for a wheelchair space when the dining and drinking surface is part of spectator seating. A fixed companion seat shall be provided adjacent to each wheelchair space.

At least 5 percent, but not less than one, accessible dining and drinking surface shall be provided at fixed dining and drinking surfaces without fixed seating per ICC A117.1 Section 902.

At least 5 percent, but not less than one, accessible dining and drinking surface shall be provided at non-fixed dining and drinking surfaces without fixed seating per ICC A117.1 Section 902.

Fixed and non-fixed dining and drinking surfaces with non-fixed seating may be combined to determine the required minimum quantity of accessible dining and drinking surfaces required.

Dining and drinking surfaces with fixed seating cannot be combined with dining and drinking surfaces without fixed seating to determine the required minimum quantity of accessible dining and drinking surfaces required.