



LANDSCAPE - SUPPLEMENT

City Maintained Landscaping Only

The following checklist provides information to be incorporated into your Subdivision Landscape Plans. All City maintained landscape designs are to be prepared by a registered Arizona Landscape Architect. All work is to conform to M.A.G. standards. At the time of submittal, a review fee is due, pursuant to the current Fee Schedule/Appendix A.2. of the Phoenix City Code. This publication can be made available in alternate formats (Braille, large print, computer diskette or audiotape) upon request. For additional information contact the Development Services Department, 200 West Washington Street, 2nd Floor, Phoenix, Arizona 85003, or call (602) 262-7811; Fax (602) 534-2642; TTY (602) 534-5500.

REVIEW OF: _____ Development Services Project # _____.

I. DESIGN CRITERIA

Provide planting, irrigation, and City details in construction documents. Plans should include the following:

- Standard plan information from landscape checklist, i.e., vicinity map, streets labeled, scale and north arrow, title block, existing vegetation, etc.
- Trees and shrubs from Arizona Department of Water Resources Low Water Use Plant List.
- Plants are to be thornless varieties. (A plant list is available from the Parks, Recreation and Library Department.)
- All planting to conform to the Street Transportation Department's site guidelines (maximum 30" height from gutter).
- Sidewalk is to be setback from curb a minimum of 8' for tree installations.
- Provide trees at 20' on center and 5 shrubs per tree, with accent plants and groundcovers. Coordinate plant types with existing street landscaping.
- Narrow planter strips at the end 10' of street median islands are to be paved if 4' or less in width. **NO TREES WITHIN 40' OF THE END OF THE MEDIAN**
- Decomposed granite (D.G.) 2" minus, 2" depth, color to be Autumn Red, Desert Gold, or other approved color. Apply pre-emergent before and after D.G. installation.
- All irrigation to be P.V.C. hard-line system with SCH 80 Flex hose risers to bubblers. Do not run lines under plants,. Emitters may be used in slope conditions greater than 4:1. Slopes 3:1 or greater must be stabilized with jute netting or reviewer approved method.
- Water meter address on plans (adjacent to meter).
- Use a dual irrigation system with separate valves (brass Rainbird or Toro) for trees and shrubs.
- Irrigation lines to be installed 6" from back of walk in public right-of-way. They shall be sleeved under trails and walks.
- All valves to be brass with one per locking box (Brooks) with a stainless steel bolt.
- Backflow preventer is to be enclosed in a security cage and screened with shrubs. Backflow device to be within 5' of meter.
- Power to controller is by an unmetered electric service. Coordinate controller location with nearest power source, obtain addressing from Project Engineering Division, Station 6, telephone number (602) 262-6551, and place address on plans adjacent to controller.
- Controller is to be installed in City cabinet as per detail. Device is to be capable of dual programs, internal transformer, cadmium battery backup, multiple repeat times, and minimum one year warranty (i.e., Rainmaster, Rainbird, and Hardy).

- [] **Parks Department staff is to perform the following inspections:**
 1. **Site grading**
 2. **Inspection for depth of trenches**
 3. **Mainline pressure test with no valves or quick couplers (150 lbs. for 2 hours)**
 4. **Depth of rototilling of amendments and fertilizer**
 5. **Plant material inspection before installation of type, size of material, and root conditions. No material that is rootbound or has circling roots will be accepted. Undersized material will not be accepted.**
 6. **Applications or pre-emergent prior to installation of D.G.**
 7. **Depth of the D.G.**
 8. **Final application of pre-emergent and the start of maintenance.**

- [] **BFPU to have a Plumbing Permit and Pressure Differentiation test approval before final inspection.**

- [] **Provide billing information, address, and account numbers of water meter and power source at the time of final acceptance by Parks Department representative.**

- [] **Schedule final inspection one (1) week prior to actual on-site inspection. Engineering inspector to set-up and attend the final inspection and final acceptance inspections with Parks Department representative.**

- [] **Subdivision block wall construction (built to final height) must be completed prior to final inspection of adjacent landscape area by Parks Department (prior to maintenance period).**

- [] **All landscape work is to have one-year maintenance period by owner after date of final inspection.**