



# Phoenix Fire Department

## Plan Review of 13-D Systems

### REFERENCED FIRE CODES

NFPA 13-D, 2002 ed. and IFC Section 903, 2003 ed.

### OBJECTIVE OF THIS CHECKLIST

This checklist is designed to guide the plan reviewer and contractor for the plan review of 13-D systems. This checklist shall be used in conjunction with the appropriate NFPA, Phoenix Fire Code, and IBC code books. This checklist is merely a general guideline to assist in the plan submittal and reviewer.

### SEQUENCED PLAN REVIEW

Reference to Phoenix Fire Code, Section 903 (Automatic Sprinkler Systems) and NFPA 13-D along with the appropriate suppressant system manual.

#### REQUIRED PLAN REVIEW INFORMATION

REQUIREMENT	Section	Complete
<u>The following points need to be addressed when conducting a plan review for 13-D systems:</u>		
<input type="checkbox"/> Verify plan has address.	903.1.2	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Verify installing contractor's information is provided on plan.	903.1.2	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Verify the plan being reviewed is a 13-D system.	903.3.1.3	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check and verify the scale.	105.2.8.1	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check to ensure the appropriate sprinkler cut sheets are included.	903.1.2	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check to ensure hydraulic calculation sheets are provided.	901.2	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Verify areas being calculated are in fact the most demanding areas.	903.1.2	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check and verify K-factor, starting GPM, and PSI, for type of sprinkler heads being calculated, are correct per data sheet.	Plan Review	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check calculations against the plans for the following: fittings, pipe sizing/lengths.	Data Sheets	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Verify 5 GPM has been deducted for domestic water supply.	Plan Review	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Verify 10 PSI has been deducted from static pressure (NOT 10%).	13D 6.3	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check spacing between sprinkler heads and spacing off walls.	903.3.1.8.3	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check coverage in areas with soffits to ensure adequate protection. (Use figure 8.10.6.1.2b in NFPA 13)	Plan Review	YES <input type="checkbox"/> NO <input type="checkbox"/>



# Phoenix Fire Department

## Plan Review of 13-D Systems

REQUIREMENT	Section	Complete
<input type="checkbox"/> Ensure garages, carports, and balconies below living spaces are covered with sprinklers.	IFC 903.3.1.3.1	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Ensure that any sprinklers that are exposed to the outside elements and subjected to freezing are insulated.	IFC 903.3.1.9	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> If a ceiling has beams and slopes, check attached flow chart and manufacturers cut sheets.	Flow Chart Cut Sheets	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check for any obstruction and reference accordingly.	NFPA 13 Section 8.10	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Check to ensure a water meter is installed and of the correct size to accommodate the sprinkling system (should be indicated on plans).	IFC 903.3.1.3.4	YES <input type="checkbox"/> NO <input type="checkbox"/>
<input type="checkbox"/> Ensure a water meter has been included and hydraulically accounted for.	IFC 903.3.1.3.4	YES <input type="checkbox"/> NO <input type="checkbox"/>